

Data sheet LI 28TES

Air-to-water heat pump for indoor installation.

Installation location:

Max. flow temperature: 60 °C

Casing colour: White (similar to RAL 9003)

Heat pump for heating purposes for indoor installation with integrated heat pump manager WPM Econ5 with standard display. The integrated control panel can also be used as a wired remote control using the wall mounting set (special accessories for MS PGD). The integrated air circuit enables corner or wall installation with air ducts at the air intake and the air outlet side. Sound-optimised through low-noise axial fan and vibration-isolated compressor. High coefficients of performance (COP) using an evaporator optimised for heating operation and energy-efficient defrosting by reverse circulation. Universal design with two compressors for output regulation when operating at partial load, optional domestic hot water preparation and flexible expansion options for:

- Bivalent or bivalent-renewable operating mode
- Distribution systems with unmixed and mixed heating circuits

At an external temperature of -10 °C, the maximum flow temperature that can be achieved is 53 °C. Dirt trap and flow rate switch built in. Flow and return sensor integrated; external sensor (standard NTC-2) in the scope of supply. Heat pump white textured (similar to RAL 9003).



Glen Dimplex Thermal Solutions
(Glen Dimplex Deutschland GmbH)
Am Goldenen Feld 18
D-95326 Kulmbach

T: + 49 9221 709-100
F: + 49 9221 709-339
dimplex@dimplex.de
www.dimplex.de

Glen Dimplex Austria GmbH
Hauptstraße 71
A-5302 Henndorf am Wallersee

T: + 43 6214 20330
F: + 43 6214 203304
info@dimplex.at
www.dimplex.at

LI 28TES

Technical data

Dimplex Air-to-water heat pump for indoor installation. (Low temperature)

Heat pump code	1019
Max. flow temperature	60 Grad
Lower operating limit heat source (heating operation) / Upper operating limit heat source (heating operation)	-20 Grad / 35 Grad
Heat output A-7/W35 / COP A-7/W35 *	11,4 kW / 2,6
Heat output max. A-7/W35 / COP A-7/W35 *	21,6 kW / 2,8
Heat output A2/W35 / COP A2/W35 *	13,4 kW / 3,1
Heat output max. A2/W35 / COP A2/W35 *	25,2 kW / 3,3
Heat output A7/W35 / COP A7/W35 *	14,5 kW / 3,2
Heat output max. A7/W35 / COP A-7/W35 *	27,8 kW / 2,8
Heat output A10/W35 / COP A10/W35 *	15,1 kW / 3,4
Heat output max. A10/W35 / COP A10/W35 *	28,3 kW / 3,6
Nominal power consumption according to EN 14511 at A2/W35	7,8 kW
Nominal power consumption A7/W35	7,9 kW
Sound power level	61 dB(A)
Refrigerant / Amount of refrigerant	R410A / 5,9 kg
Max. heating water flow rate / Pressure drop	5,3 m3 pro h / 21000 Pa
Heat source flow (min.)	6000 m3 pro h
Width x Height x Depth **	750 x 1710 x 1030 mm
Weight	326 kg
Rated voltage	3/N/PE ~400 V, 50 Hz
Starting current	28 A
Type of defrosting	Reverse circulation
Heat pump seal of approval (valid until)	Yes / 29.10.2024

*Heat output and coefficient of performance (COP) according to EN 14511

**Please note that additional space is required for pipe connections, operation and maintenance.



Glen Dimplex Thermal Solutions T: + 49 9221 709-100
(Glen Dimplex Deutschland GmbH) F: + 49 9221 709-339
Am Goldenen Feld 18 dimplex@dimplex.de
D-95326 Kulmbach www.dimplex.de

Glen Dimplex Austria GmbH T: + 43 6214 20330
Hauptstraße 71 F: + 43 6214 203304
A-5302 Henndorf am Wallersee info@dimplex.at
www.dimplex.at

LI 28TES

Description	Order ref.	Article number	Sample item	Item
Heat pumps				
Elasticated sound insulation underlay strips	SYL 250	352260	1	
DN 32 double-sphere rubber expansion joint	KOMP 32	362060	0	
DN 32 dirt trap	SMF 32	362140	0	
Hydraulic accessories				
Heating water hose connection set	SAS 110	340330	0	
El. cont. circulating pump: Control type Δp -c, fixed speed; PWM control optional	UPE 80-32PK	380170	0	
Hydraulic tower 300 litres	HPK 300	371600	1	
Immersion heater 4.5 kW; ~400 V	CTHK 633	322140	0	
Immersion heater 6.0 kW; ~400 V	CTHK 634	322150	0	
Transport aid for Hydro-Tower / LAW indoor unit	TH 270	370430	0	
Free-standing buffer tank 200 l	PSW 200	339830	0	
Universal buffer tank (500 l)	PSW 500	339210	0	
Dual differential pressureless manifold	DDV 40	367720	0	
High-efficiency wet-running pump PWM with coupling relay	UPH 120-32PK	375750	0	
Manifold bar DN 32	VTB 32-2	374920	0	
Manifold bar DN 32	VTB 32-3	374930	0	
Domestic hot water module/unmixed heating circuit module	WWM 32	367800	0	
Mixed heating circuit module	MMH 32	367790	0	
Mixer module for bivalent systems	MMB 32	367780	0	
Electronically controlled wet-running pump, self-regulating	UPE 100-32K	374730	0	



Glen Dimplex Thermal Solutions T: + 49 9221 709-100
 (Glen Dimplex Deutschland GmbH) F: + 49 9221 709-339
 Am Goldenen Feld 18 dimplex@dimplex.de
 D-95326 Kulmbach www.dimplex.de

Glen Dimplex Austria GmbH T: + 43 6214 20330
 Hauptstraße 71 F: + 43 6214 203304
 A-5302 Henndorf am Wallersee info@dimplex.at
 www.dimplex.at

Data sheet LI 28TES

Description	Order ref.	Article number	Sample item	Item
Electronically controlled wet-running pump, self-regulating	UPE 120-32K	374740	0	
Ready-for-use DN 32 stainless steel Wellflex pipe	VSE 32-50	362520	0	
Ready-for-use DN 32 stainless steel Wellflex pipe	VSE 32-100	362530	0	
Ready-for-use DN 32 stainless steel Wellflex pipe	VSE 32-150	362540	0	
Ready-for-use DN 32 stainless steel Wellflex pipe	VSE 32-200	362550	0	
Ready-for-use DN 32 stainless steel Wellflex pipe	VSE 32-300	362560	0	
Immersion heater pipe assembly	HDLR 450	337450	0	
Heating accessories				
Fan convector heating with EC fan	SRX 080EM	367500	0	
Fan convector heating with EC fan	SRX 120EM	367510	0	
Fan convector heating with EC fan	SRX 140EM	367520	0	
Fan convector heating with EC fan	SRX 180EM	367530	0	
DHW preparation accessories				
500 l solar cylinder for heat pump	WWSP 540 SOL	361090	12	
Domestic hot water cylinder (400 l) with temperature sensor	WWSP 442	372840	1	
Flange heater for domestic hot water	FLH 60	338060	0	
Flange heater for domestic hot water	FLHU 70	338070	0	
FLH 25M flange heater	FLH 25M	349430	0	



Glen Dimplex Thermal Solutions T: + 49 9221 709-100
 (Glen Dimplex Deutschland GmbH) F: + 49 9221 709-339
 Am Goldenen Feld 18 dimplex@dimplex.de
 D-95326 Kulmbach www.dimplex.de

Glen Dimplex Austria GmbH T: + 43 6214 20330
 Hauptstraße 71 F: + 43 6214 203304
 A-5302 Henndorf am Wallersee info@dimplex.at
 www.dimplex.at

Data sheet LI 28TES

Description	Order ref.	Article number	Sample item	Item
Safety valve combination	SVK 852	326660	0	
Domestic hot water cylinder (500l) with temperature sensor	WWSP 556	370080	0	
Domestic hot water cylinder, 700 litres	WWSP 770	376730	0	
Pump unit DN 32 for direct connection of the domestic hot water cylinder	WPG 32	356040	0	
High-efficiency circulating pump DN 32 with coupling relay	UPH 90-32	370420	0	
3-way reversing valve DN 32	DWV 32	374780	0	
Control accessories				
Extension for an Ethernet network connection	NWPM	356960	0	
Expansion module WPM for a KNX/EIB connection	KNX WPM	376350	0	
Extension for a Modbus RTU connection	LWPM 410	339410	0	
Swimming pool/remote fault indicator relay module	RBG WPM	339700	0	
Remote control for WPM 2006/2007/EconPlus/R	AP PGD	356570	0	
Outside temperature sensor with casing	FG 3115	336620	0	
Temperature sensor NTC-10 with metal sleeve	NTC-10M	363600	0	

* Other specific accessories available / required

Important information:

The combination of the components and the quantities indicated represent a non-binding sample system, which needs to be tested and individually adapted as required. Pump dimensioning must be reviewed according to the pressure loss of the system and the minimum heating water flow rate of the heat pump.



Glen Dimplex Thermal Solutions T: + 49 9221 709-100
 (Glen Dimplex Deutschland GmbH) F: + 49 9221 709-339
 Am Goldenen Feld 18 dimplex@dimplex.de
 D-95326 Kulmbach www.dimplex.de

Glen Dimplex Austria GmbH T: + 43 6214 20330
 Hauptstraße 71 F: + 43 6214 203304
 A-5302 Henndorf am Wallersee info@dimplex.at
 www.dimplex.at


LI 28TES

Note:

The given hydraulic integration schematic is a schematic representation of the key components and serves as an aid for planning your customized system. The current status is available at all times under www.dimplex.de/nc/en/professional/online-planner/hydraulic-integrations.html. It does not contain all the required safety devices, the components needed to maintain constant pressure, or any other additional valves which may be required for maintenance and service work as stipulated by EN 12828.

The heat pump manager settings and any external regulation system which may be connected must be adapted to the present integration diagram.

Software updates may be required!



Glen Dimplex Thermal Solutions
 (Glen Dimplex Deutschland GmbH)
 Am Goldenen Feld 18
 D-95326 Kulmbach

T: + 49 9221 709-100
 F: + 49 9221 709-339
 dimplex@dimplex.de
 www.dimplex.de

Glen Dimplex Austria GmbH
 Hauptstraße 71
 A-5302 Henndorf am Wallersee

T: + 43 6214 20330
 F: + 43 6214 203304
 info@dimplex.at
 www.dimplex.at

LI 28TES

System description:

- Air-to-water heat pumps with defrosting by reverse circulation extract the energy required for defrosting from the heating system. In the case of air-to-water heat pumps, a buffer tank connected in series, into which the immersion heater is screwed, must be installed in the flow in mono energy systems to ensure defrosting. A dirt trap with a mesh size of between 0.6mm and 0.8mm is to be installed in order to protect the plate heat exchanger from larger dirt deposits. Clean the filter sieve of the dirt trap one day after start-up. These intervals can be extended as soon as no more impurities are detected. When the level of impurities is significantly high (e.g. due to corrosion found in the building), it is recommended that a sludge trap be installed in order to minimise the need for regular cleaning. A permanent corrosion process, caused by the entry of oxygen into the system, is characteristic of heating systems featuring open diffusion. This is best alleviated using an electrophysical anti-corrosion system. Condensate which forms during defrosting must be drained off without risk of frost. Acoustic emissions must be taken into account, and a free air circuit provided for, when the installation location is being selected. Heat pumps without weather-proof protective covers in particular need to be installed outdoors in such a manner that the air outlet is not positioned against the main wind direction.
- A buffer tank connected in series is recommended for heat pump heating systems, to ensure the minimum heat pump runtime of 6 minutes for all operating statuses.
- The heat pump supplies a large part of the required heat output. An electric heating element (immersion heater) supplements the heat pump on days when the external temperature lies below the bivalence point. In mono energy systems, the contactor for the immersion heater (E10.1) must be set according to the output. It is controlled (230 V AC) by the heat pump manager via terminals X1/N and J13/NO4.
- During silent cooling, the water temperature must always be kept above the dew point temperature. A room climate control station (RKS WPM) must be installed in a reference room so that the permissible flow temperature can be set based on the measured room temperature and air humidity. At vulnerable points of the cooling distribution system, additional dew point sensors can be used to interrupt cooling operation when condensate forms.
- The minimum heating water flow through the heat pump is maintained in all operating states by hydraulic decoupling of the generator circuits from the consumer circuit.

Presettings:

.....
.....
.....
.....
.....
.....
.....
.....
.....
.....



Glen Dimplex Thermal Solutions
(Glen Dimplex Deutschland GmbH)
Am Goldenen Feld 18
D-95326 Kulmbach

T: + 49 9221 709-100
F: + 49 9221 709-339
dimplex@dimplex.de
www.dimplex.de

Glen Dimplex Austria GmbH
Hauptstraße 71
A-5302 Henndorf am Wallersee

T: + 43 6214 20330
F: + 43 6214 203304
info@dimplex.at
www.dimplex.at

LI 28TES



Glen Dimplex Thermal Solutions
(Glen Dimplex Deutschland GmbH)
Am Goldenen Feld 18
D-95326 Kulmbach

T: + 49 9221 709-100
F: + 49 9221 709-339
dimplex@dimplex.de
www.dimplex.de

Glen Dimplex Austria GmbH
Hauptstraße 71
A-5302 Henndorf am Wallersee

T: + 43 6214 20330
F: + 43 6214 203304
info@dimplex.at
www.dimplex.at

LI 28TES

Legend:

- 1. Heat Pump
- 1.1 Air-to-water heat pump
- 1.2 Brine-to-water heat pump
- 1.3 Water-to-water heat pump
- 1.4 Reversible air-to-water heat pump
- 1.5 Reversible brine-to-water heat pump
- 1.6 Reversible water-to-water heat pump
- 1.7 Air-to-water heat pump split design
- 10. Heating circuit only
- 13. Heat source
- 15. Hydraulic tower
- 16. Scalding protection
- 17. Hydro tower HWK 332
- 2. Heat pump manager
- 3. Parallel buffer tank
- 3.1 Buffer tank
- 4. Hot water cylinder
- 5. Swimming pool heat exchanger
- 6. Passive cooling station with cooling controller N6
- 7. Heating and silent or dynamic cooling
- 8. Fan convector with 4-wire connection
- 9. Cooling circuit only

Domestic hot water distribution system:

- In combination with EB KPV (up to 2.0 m³/h)*
- DDV 25 Dual differential pressureless manifold (up to 2.0 m³/h)*
- DDV 32 Dual differential pressureless manifold (up to 2.5 m³/h)*
- EB KPV Extension module for compact manifold (up to 2.0 m³/h)*
- KPV 25 Compact manifold with overflow valve (up to 1.3 m³/h)*
- MMB 25 Mixer module, bivalent (up to 2.0 m³/h)*
- MMH 25 Mixer module for heating circuit
- VTB 25 Manifold bar (up to 2.5 m³/h)*
- WWM 25 Hot water module / unmixed heating circuit (up to 2.5 m³/h)*

* Recommended max. heating waterflow



Glen Dimplex Thermal Solutions
(Glen Dimplex Deutschland GmbH)
Am Goldenen Feld 18
D-95326 Kulmbach

T: + 49 9221 709-100
F: + 49 9221 709-339
dimplex@dimplex.de
www.dimplex.de

Glen Dimplex Austria GmbH
Hauptstraße 71
A-5302 Henndorf am Wallersee

T: + 43 6214 20330
F: + 43 6214 203304
info@dimplex.at
www.dimplex.at

LI 28TES

Solarthermics:

SOLCU 1	Solar controller	M21	Mixer
SOLPU 1	Solar station	M22	Mixer heating/cooling circuit 2
SST 25	Solar station for hot water	M25	Circulating pump for heating and domestic hot water preparation
T1	Temperature sensor (collector sensor)	N1	Heating controller
T2	Temperature sensor (cylinder 1)	N12	Solar controller
T3	Temperature sensor (cylinder 2 /optional display function)	N17.1	Cooling module general
B3	Hot water thermostat	N17.2	Cooling module active
B4	Swimming pool thermostat	N17.3	Cooling module passive
B7	Thermostat primary circuit	N17.4	Solar module WPM Econ SOL
E10	2nd heat generator (HG2)	N2	Cooling controller for reversible heat pumps
E10.1	Immersion heater	N3	Room climate control stations
E10.2	Oil/gas boiler	R1	External wall sensor
E10.3	Solid fuel boiler	R11	Flow sensor for cooling water
E10.5	Solar energy system	R13	Sensor for heating circuit 3 / bivalent-renewable
E9	Flange heater, hot water	R2	Return flow sensor
F10	Flow rate switch	R3	Hot water sensor
F7	Safety temperature monitor	R4	Return flow sensor for cooling water
K20	Contactora for 2nd heat generator	R5	Temperature sensor for heating circuit 2
K21	Contactora for immersion heater hot water	R9	Flow sensor (antifreeze)
M11	Primary pump for heating operation	SMF	Dirt trap
M12	Primary pump for cooling operation	TC	Room temperature controller
M13	Heat circulating pump for main circuit	Y12	External 4-way reversing valve
M14	Heat circulating pump for heating circuit 1	Y13	Three-way reversing valve
M15	Heat circulating pump for heating circuit 2	Y5	Three-way distribution valve
M16	Auxiliary circulating pump	Y6	Two-way valve
M17	Cooling circulating pump	Y7	Three-way mixing valve
M18	Hot water circulating pump	Y8	Three-way valve (closing time max. 10 sec.)
M19	Swimming pool water circulating pump		
M20	Heat circulating pump heating /cooling circuit 3 still		



Glen Dimplex Thermal Solutions
(Glen Dimplex Deutschland GmbH)
Am Goldenen Feld 18
D-95326 Kulmbach

T: + 49 9221 709-100
F: + 49 9221 709-339
dimplex@dimplex.de
www.dimplex.de

Glen Dimplex Austria GmbH
Hauptstraße 71
A-5302 Henndorf am Wallersee

T: + 43 6214 20330
F: + 43 6214 203304
info@dimplex.at
www.dimplex.at